

|   |  |                                  |  |   |  |   |  |
|---|--|----------------------------------|--|---|--|---|--|
| AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT  |  |                                  |  | 1. CONTRACT ID CODE   |  | PAGE OF PAGES<br>1   2                                |  |
| 2. AMENDMENT/MODIFICATION NO.<br>0001   |  | 3. EFFECTIVE DATE<br>23-Jan-2001 |  | 4. REQUISITION/PURCHASE REQ. NO.<br>W26GLG-0346-9623                                |  | 5. PROJECT NO.(If applicable)                         |  |
| 6. ISSUED BY<br>CONTRACTING DIVISION<br>US ARMY ENGR DIST NORFOLK ATTN: CENAO-CT 803 FRONT STREET<br><br>NORFOLK, VA 23510-1096   |  | CODE<br>DACA65                   |  | 7. ADMINISTERED BY (If other than item 6)<br><br><b>See Item 6</b>                  |  | CODE  |  |
| 8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)   |  |                                  |  | X   |  | 9A. AMENDMENT OF SOLICITATION NO.<br>DACA65-01-B-0005 |  |
|   |  |                                  |  | X   |  | 9B. DATED (SEE ITEM 11)<br>16-Jan-2001                |  |
|   |  |                                  |  |   |  | 10A. MOD. OF CONTRACT/ORDER NO.                       |  |
|   |  |                                  |  |   |  | 10B. DATED (SEE ITEM 13)                              |  |
| CODE  |  | FACILITY CODE                    |  |   |  |   |  |
| 11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS   |  |                                  |  |   |  |   |  |
| <input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended.<br><br>Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods:<br>(a) By completing Items 8 and 15, and returning _____ copies of the document; (b) By acknowledging receipt of this amendment on each copy of the offer submitted;<br>or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE<br>RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN THE<br>REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter,<br>provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified. |  |                                  |  |   |  |   |  |
| 12. ACCOUNTING AND APPROPRIATION DATA (If required)   |  |                                  |  |   |  |   |  |
| 13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS.<br>IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.   |  |                                  |  |   |  |   |  |
| A.THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.   |  |                                  |  |   |  |   |  |
| B.THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).  |  |                                  |  |   |  |   |  |
| C.THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:   |  |                                  |  |   |  |   |  |
| D.OTHER (Specify type of modification and authority)  |  |                                  |  |   |  |   |  |
| E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.   |  |                                  |  |   |  |   |  |
| 14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)<br>AMENDMENT NO. 0001 to DACA65-01-B-0005   |  |                                  |  |   |  |   |  |
| Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.  |  |                                  |  |   |  |   |  |
| 15A. NAME AND TITLE OF SIGNER (Type or print)   |  |                                  |  | 16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)<br>DEBORA S GRAY / .     |  |   |  |
| 15B. CONTRACTOR/OFFEROR<br><br>_____<br>(Signature of person authorized to sign)  |  | 15C. DATE SIGNED                 |  | 16B. UNITED STATES OF AMERICA<br><br>BY _____<br>(Signature of Contracting Officer) |  | 16C. DATE SIGNED<br><br>23-Jan-2001                   |  |

## SECTION SF 30 BLOCK 14 CONTINUATION PAGE

## 1. SECTION 00100

- a. THIS IS A 100% SMALL BUSINESS SET ASIDE PROCUREMENT.
- b. There will be a PREPROPOSAL CONFERENCE on subject project to be held FEBRUARY 6, 2001 at 9:00 am at the Southwestern Virginia Area Office; Bldg 449, Radford Army Ammunition Plant, Radford, VA. Due to security of the plant , contractors need to make reservations with the Field Office (Bill Wright) at 540-639-7656 no later than February 5, 2001 at noon. All questions must be put in writing and may be submitted prior to this conference to Debbie Gray at (757)441-7183 {fax} no later than February 1, 2001, Noon. This will be the only time the site will be available for this project.

## 2. Technical plans and specifications are amended.

**AMENDMENT**

**NO. 1**

**January 22, 2001**

# **SPECIFICATIONS**

## **1. Specification Section 01055**

This specification section is removed in its entirety.

## **2. Specification Section 01006**

### **a) Paragraph 1.10.3 on Page 8**

In the last sentence change the word "User" to "Plant Operating Contractor".

## **2. Specification Section 01111**

### **a) Paragraph 1.1 under Code of Federal Regulations add:**

29 CFR 1926

Safety and Health Regulations for Construction

# **DRAWINGS**

## **1. Sheet G-3**

This sheet is replaced in its entirety by new Sheet G-3.

## **2. Sheet C-9**

### **a) Note 3**

Replace the entire note with the following:

"Contractor is made aware that there are existing overhead structures which will make the excavation and installation of the Wet Well difficult. The Contractor shall take the necessary precautions to protect the existing NAC/SAC Building #735-2 and all existing underground utility systems in the vicinity from damage and/or settlements in accordance with the criteria of the COE's Safety and Health Requirements Manual, EM385-1-1."

## **3. Sheet C-14**

### **a) General Note**

Replace the entire note with the following:

"Construction for tie-in into existing 36" Acid Sewer line shall be performed during one week periods of plant shutdown (December 25th and July 4th timeframe) when acid wastewater production is ceased. Contractor shall coordinate tie-in schedule with the COR and the Plant Operating Contractor's Operations Officer. Contractor shall provide bypass pumping capability (500 gpm minimum requirement) for Powerhouse cooling water during scheduled tie-in."

#### **4. Sheet C-20**

##### **a) Note 2**

Replace the entire note with the following:



"Construction for tie-in into existing 36" Acid Sewer line shall be performed during one week periods of plant shutdown (December 25th and July 4th timeframe) when acid wastewater production is ceased. Contractor shall coordinate tie-in schedule with the COR and the Plant Operating Contractor's Operations Officer. Contractor shall provide bypass pumping capability (500 gpm minimum requirement) for Powerhouse cooling water during scheduled tie-in."

#### **5. Sheet C-30**

See Sketch C-30.1 attached.

#### **6. Sheet E-1**

This sheet is replaced in its entirety by new sheet E-1.



PUMP STATION CONCRETE SLAB AT  
PRE-CAST CONCRETE TANK DETAIL

NOT TO SCALE

SKETCH C-30.1